



SAFE T FIRST

## Aboveground Storage Tank Monthly Inspection

Dealership: \_\_\_\_\_

Inspector: \_\_\_\_\_

PBS#: \_\_\_\_\_

Month / Year: \_\_\_\_\_

\*\*\*\*\*TANK NUMBER\*\*\*\*\*

Enter Tank Number as it reads on permit →

--	--	--	--	--	--	--	--	--	--

Comments

Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Is tank exterior/dike free of rust, and surrounding area free of visible leaks?

--	--	--	--	--	--	--	--	--	--	--

Is the tank product level gauge, alarm and overflow prevention equipment readable/audible and in good working condition?

--	--	--	--	--	--	--	--	--	--	--

Is the tank identified with design & working capacity, ID # and color coded if applicable?

--	--	--	--	--	--	--	--	--	--	--

Does the facility conduct monthly inspections for all AST systems?

--	--	--	--	--	--	--	--	--	--	--

**Containment (Diking/Impounding)**

Is the containment (dike) free of liquid, debris, and flammable materials?

--	--	--	--	--	--	--	--	--	--	--

Are dike drain valves closed, locked, and in good working condition?

--	--	--	--	--	--	--	--	--	--	--

**Double-Wall Tanks...**

Is interstice free of liquid?

--	--	--	--	--	--	--	--	--	--	--

Is interstitial monitoring equipment in good working condition?

--	--	--	--	--	--	--	--	--	--	--

6 NYCRR Part 613-4.2(d)(1)-(3) requires that all ASTs be visually inspected at least monthly and records maintained for at least 3 years.

**Provided to you as a service of the Niagara Frontier Automobile Dealers Association (NFADA)—716-631-8510**